

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7260-1394:0122 Page 1 of 1

CATEGORY: 7260 -- SMOKE DETECTION SYSTEM-BEAM TYPE

LISTEE: APOLLO FIRE DETECTORS LTD36 Brookside Rd, Havant, Hampshire, P09 1JR United Kingdom
 Contact: Clifton Gare-Mogg 44 (0) 23 9249 2412 Fax 44 (0) 23 9249 2754
 Email: clifton.gare-mogg@apollo-fire.co.uk

DESIGN: XP95A Series Model 55000-266 projected beam smoke detector. Unit consists of a transmitter, receiver and a control box. Refer to the listee's data sheet for detailed product description and operational considerations.

RATING: 14-28 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as projected beam smoke detector for use with separately listed compatible fire alarm control units.

04-21-11 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO**, Program Coordinator
 Fire Engineering Division