

Certificate of constancy of performance,

0832-CPR-F0607

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

55000-741 Loop-Powered Type A VAD 6m (Red)

(For full product details and conditions of use refer to appendix)

Produced by or for

Apollo Fire Detectors Ltd

**36 Brookside Road
Havant
Hampshire
PO9 1JR
United Kingdom**

and produced in the manufacturing plant(s)

Apollo Fire Detectors Ltd

**36 Brookside Road
Havant
Hampshire
PO9 1JR
United Kingdom**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-23:2010 - Visual alarm devices

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 08 January 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



P Halligan, Certification Manager
On behalf of BRE Global Limited
Date of issue: 23 December 2016
Issue number: 03

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR-F0607

Notes:

1. The wall mounted VAD meets the requirements of EN 54-23:2010 for the following:
 - Category rating W-2.4-6
 - Synchronization
 - Flash rate 0.5 Hz
 - White LED
 - Clear lens
2. Approved with XP95/Discovery 45681-210 mounting base and 45681-284 short circuit isolating base

Bases:

- 45681-210 XP95/Discovery mounting base
45681-284 XP95/Discovery short circuit isolating base



P Halligan, Certification Manager
On behalf of BRE Global Limited
Date of issue: 23 December 2016
Issue number: 03

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.