



Date Of Issue – 13 March 2009
Construction Products Directive 89/106/EEC

APOLLO FIRE DETECTORS LTD
DECLARATION OF CONFORMITY

This document is a declaration that the products identified below conform to the essential requirements that have been specified in the Construction Products Directive 89/106/EEC. This Directive has been enacted into UK law by the Construction Products Regulations 1991 as amended by the Construction Products (Amendment) Regulations 1994.

Product Range	Interfaces
Part Numbers	55000-845
Description	Analogue addressable Zone Monitor Unit with Isolator


This product is manufactured at the premises of Apollo Fire Detectors Ltd., 36 Brookside Road, Havant, Hampshire, England PO9 1JR.

An EC Certificate of Conformity has been granted for this product by the Notified Body the Loss Prevention Certification Board, Bucknalls Lane, Garston, Watford, Hertfordshire, WD25 9XX, UK. The identification number of this Notified Body is 0832.

This product is compliant with the provisions of Annex ZA of the standard listed below.

- | | | |
|---|-----------------|--|
| 1 | EN 54 – 17:2005 | Fire detection and alarm systems – Short Circuit Isolators |
| 2 | EN 54 – 18:2005 | Fire detection and alarm systems – Input/Output Devices |

This declaration is made for and on behalf of Apollo Fire Detectors by the Head of Technical Sales, Mr Jeff Cutler, who has been designated as the responsible person for the purpose of the Regulations.

Signature  Mr J Cutler – Head of Technical Services