



Marine & Offshore
Division

Certificate number: 14061/C0 BV

File number: AP 3633

Product code: 3788H

This certificate is not valid when presented without the full attached schedule composed of 7 sections

www.veristar.com

TYPE APPROVAL CERTIFICATE

This certificate is issued to

APOLLO FIRE DETECTORS LIMITED

Havant - UNITED KINGDOM

for the type of product

FIRE DISCONNECTION UNITS

Orbis / Orbis IS - TimeSaver Base & Conventional Relay Base.

Requirements:

BV Rules for the Classification of Steel Ships.
EN 54-7 (2002) & EN 54-5 (2002).

This certificate is issued to attest that BUREAU VERITAS did undertake the relevant approval procedures for the product identified above which was found to comply with the relevant requirements mentioned above.

This certificate will expire on: 13 Nov 2019

For BUREAU VERITAS,

At BV LONDON, on 13 Nov 2014,
Spencer Yule



This certificate remains valid until the date stated above, unless cancelled or revoked, provided the conditions indicated in the subsequent page(s) are complied with and the product remains satisfactory in service. This certificate will not be valid if the applicant makes any changes or modifications to the approved product, which have not been notified to, and agreed in writing with BUREAU VERITAS. Should the specified regulations or standards be amended during the validity of this certificate, the product(s) is/are to be re-approved prior to it/they being placed on board vessels to which the amended regulations or standards apply. This certificate is issued within the scope of the General Conditions of BUREAU VERITAS Marine & Offshore Division available on the internet site www.veristar.com. Any Person not a party to the contract pursuant to which this document is delivered may not assert a claim against BUREAU VERITAS for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by personnel of the Society or of its Agents in establishment or issuance of this document, and in connection with any activities for which it may provide.

The electronic version is available at: <http://www.veristarnb.com/veristarnb/jsp/viewPublicPdfTypepec.jsp?id=y3c436mmpw>
BV Mod. Ad.E 530 October 2014

This certificate consists of 3 page(s)

THE SCHEDULE OF APPROVAL

1. PRODUCT DESCRIPTION :

| Orbis / Orbis IS - Fire Detector Connection Bases | |
|--|--|
| Orbis Part Number | Description |
| ORB-MB-00001-MAR | TimeSaver base |
| ORB-RB-40004-MAR | Relay base |
| ORB-MB-50018-APO | IS TimeSaver base |
| ORB-BA-50008-APO | IS Base Adaptor (in conjunction with 45681-207 base) |

2. DOCUMENTS AND DRAWINGS :

2.1 - Drawings specification N°s: 300-MA-00003, 47000-478, 47000-485, 100-RB-00007Rev.2, ORB-RB-10004, 400-RB-00007, 300-MA-00005, 39821-897, 39800-048, 200-RB-00005 Rev.4, 39214-214, 300-MA-00011_CS, Rev.2, 400-BA-00014_CS.

2.2 - Installation guide ref: 39214-104/Issue 9.

2.3 - Product guide ref: PP2250 IS PG.

3. TEST REPORTS :

3.1 - BRE/LPCB test reports N°s:

- 210362 dated 05 Jan. 2004
- 210363 dated 05 Jan. 2004
- 211499 dated 05 Jan. 2004
- 210364 dated 05 Jan. 2004
- 211500 dated 05 Jan. 2004
- 120739/2.1 dated 15 Aug. 2006

3.2 - Apollo test reports N°s:

- 1840.0 dated 10 Sep. 2004
- 1884.0 dated 10 Sep. 2004
- 1841.0 dated 10 Sep. 2004

3.3 - Baseefa certificate N° 06ATEX0007X

4. APPLICATION / LIMITATION :

4.1 - The Associated fire alarm central unit used with the above equipment (cf. clause 1) shall be Type approved.

4.2 - Approval also valid for ships to be granted with the notations: **AUT-UMS, AUT-CCS, AUT-PORT and AUT-IMS.**

4.3 - Approval also valid for ships having to comply with SOLAS 74 Convention, as amended, and for units having to comply with IMO Resolution A649 (The "MODU Code").

4.4 - The fitting aboard to be the same as used for the test.

4.5 - All Intrinsically Safe (IS) Products must incorporate a certified safety barrier or interface to limit the voltage and power to the circuit.

4.6 - Intrinsically safety type Time saver base and Base adaptor EEx ia IIC T4 may be used in areas considered as dangerous due to the presence of flammable or explosive gases or vapours corresponding to the group IIC and to the temperature class T4 defined in IEC Classification, in accordance with BASEEFA certificates at Clause 3 above.

4.7 - Satisfactory performance tests should be witnessed on each installation by the Society's Surveyor after installation on board.

4.8 - An instruction manual covering operation, maintenance and testing should be placed on board each ship fitted with this Unit.

5. PRODUCTION SURVEY REQUIREMENTS :

5.1 - The above products are to be supplied by **APOLLO FIRE DETECTORS LIMITED** in compliance with the type described in this certificate.

5.2 - This type of product is within the category HBV of Bureau Veritas Rule Note NR320.

5.3 - **APOLLO FIRE DETECTORS LIMITED** has to make the necessary arrangements to have its works recognised by Bureau Veritas in compliance with the requirements of NR320 for HBV products :

APOLLO FIRE DETECTORS LIMITED
36 Brookside Road
Havant
Hampshire
UNITED KINGDOM

6. MARKING OF PRODUCT :

- Maker's name or trade mark.
- Serial number of the units.
- Equipment type number or model identification under which it was type-tested.
- Ex. Informations, as relevant.

7. OTHERS :

7.1 - This approval is given on the understanding that the Society reserves the right to require check tests to be carried out on the Equipment at any time, and that **APOLLO FIRE DETECTORS LIMITED, Havant - United Kingdom** will accept the responsibility for informing shipbuilders or their sub-contractors of the proper methods of use and general maintenance of the Equipment and the conditions of this approval.

7.2 - This certificate supersedes the Type Approval Certificate No. 14061/B0 BV issued on 09 Sep 2009 by the Society

*** END OF CERTIFICATE ***