

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7270-1394:0112

Page 1 of 1

**CATEGORY:** 7270 -- HEAT DETECTOR

**LISTEE:** APOLLO FIRE DETECTORS LTD36 Brookside Rd, Havant, Hampshire, P09 1JR United Kingdom  
Contact: Stephen Wells 44 (0) 23 9249 2412 Fax 44 (0) 23 9249 2754  
Email: stephen.wells@apollo-fire.com

**DESIGN:** Series 65A Models 55000-138, -139, -140, -141, -142, -143, -144, -145, -146 combination electronic/fixed temperature heat detectors. \*Models 55000-139, -142, and -145 have the addition of a LED that flashes in the quiescent state. \*Models 55000-138, -141, and -144 have the addition of a LED that flashes in the quiescent state and a magnet operated test switch. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** Electrical: 9 - 33 VDC

55000-138, 55000-139, 55000-140: 135 ° F  
55000-141, 55000-142, 55000-143: 170 ° F  
55000-144, 55000-145, 55000-146: 200 ° F

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as heat detectors for use with listee's separately listed compatible fire alarm control unit and listed \*Series 65A Models 45681 Series detector bases (CSFM Listing No. 7300-1394:109) and \*Series 60A Models 45681-200, -220, -232 and -251 detector bases (CSFM Listing No. 7300-1394:106). Refer to listee's Installation Instruction Manual for details.

Rev. 06-20-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO, Program Coordinator**  
*Fire Engineering Division*