

TEST CERTIFICATE No. 2559710N

In accordance with clause 12 of the Standard Law - 1953

DETAILS OF ORDER:

The test was ordered by: Apollo Fire Detectors Limited
Address: 6 Solent road, Havant, Hampshire, England.
Date of order: 27/12/95

DESCRIPTION OF SAMPLES:

Ionization detectors type: 55000-550 manufactured by Apollo, U.K.

NATURE OF TEST:

Testing the compliance of the samples with the Israeli Standard SI 1220 part 1- "FIRE PROTECTIVE SIGNALING SYSTEMS": SMOKE DETECTORS, September 1985.

This certificate contains 2 pages and may be used only in full.

This certificate refers to the tested specimens only and does not apply to other items of the same product.

This certificate alone is not sufficient for the release of goods from Customs.

1. GENERAL:

A representative of the test sponsor, submitted for tests 28 detectors type 55000-550 manufactured by Apollo, U.K. The detectors were marked with numbers from 57001 up to 57028. The detectors were tested with an Analog fire alarm control panel model Epsilon manufactured by Moran Israel.

2. CONCLUSIONS:

The detectors which have been tested, comply with the requirements of the Standard.

.../2

The original Test Certificate was signed by:

Name: A. Azoulay
Position: Test Technican

Name: B. Zolonez

I confirm that this is a true translation of the Hebrew original. Only the original test certificate is authentic.

Name: Eng. Z. Egozi
Position: Head of Electronics Laboratory

3. TEST RESULTS:

3.1 The detectors are marked with the following:



3.2 All other positive test results are kept in the institution in the original file of the certificate.

3.3 The results of the tests with gray smoke and black smoke are presented in Appendix A.

* * *

AD/01/01/98