

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1394:0108 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: APOLLO FIRE DETECTORS LTD36 Brookside Rd, Havant, Hampshire, P09 1JR United Kingdom
Contact: Stephen Wells 44 (0) 23 9249 2412 Fax 44 (0) 23 9249 2754
Email: stephen.wells@apollo-fire.com

DESIGN: XP95A analog addressable signaling/contact monitoring modules. Model 55000-805 switch monitor module, Model 55000-806 priority switch monitor module, Model 55000-820 switch monitor input-output module, Model 55000-825 sounder control module, Model 55000-830 mini priority switch monitor module and Model 55000-831 mini switch monitor module. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 17 to 28 VDC, 5 to 9 V protocol

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as monitoring modules for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

*Rev. 06-20-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division