

Monday, 30 October 2023

## Technical Bulletin (TB-2306): XP95 Marine Flame Detector (UV) – Base Mounted

### Reason for notification:

This product no longer holds MED approval.

Model number	Item Name
55000-027MAR	XP95 Flame Detector (UV) - Base Mount

### Detail:

We have made the decision not to reapply for MED approval for this product at this time. All MED logos and marks will be removed from the product, labels, and packaging.

The XP95 Marine Flame Detector (UV) still holds other marine type approvals, including Lloyds Register and CCS, therefore it still approved for use in marine projects.

### Remedy

If you are happy to accept this product without MED approval, you do not need to do anything. Once stock has arrived your order will be shipped.

If you cannot accept this device without MED approval, please cancel your order at the earliest opportunity by contacting our customer service team: [sale.enquiries@apollo-fire.com](mailto:sale.enquiries@apollo-fire.com)

### Questions

If you have any questions, please contact your account manager or email [sales.enquiries@apollo-fire.com](mailto:sales.enquiries@apollo-fire.com)

-END-