



MONDAY, 02 OCTOBER 2023

Update to Technical Bulletin (TB-2106): Flame Detectors

Reason for notification:

Update to TB-2106 regarding estimated dates for resumption of supply for flame detectors.

Detail:

As previously advised, following a component obsolescence, our supplier has identified and is migrating to the alternative IR sensor component requiring re-approval. Unfortunately, there has been a delay in the approval schedule resulting in standard products and base mounts having different availability dates.

Please refer to the tables below for individual product numbers and estimated resumption dates.

IR2, IR3 and UV/IR2 product dates

Approval	Estimated Approval Completion	Estimated resumption of Stock into Apollo
BRE, UKCA, LPCB	December 2023	January 2024

All products of the model numbers identified below are affected by this issue.

Model number	Item Name
55000-019	Conv. Flame Detector (IR3)
55000-020	XP95 Flame Detector (IR3)
55000-021	XP95 Exd Flame Detector (IR3) - Flameproof
55000-060	Conv. Flame Detector (IR2)
55000-061	Conv. Exd Flame Detector (IR2) - Flameproof
55000-062	Conv. Exd Flame Detector (IR3) - Flameproof
55000-063	Conv. I.S. Flame Detector (IR3)
55000-064	Conv. Flame Detector (UV/IR2)
55000-065	Conv. Exd Flame Detector (UV/IR2) - Flameproof
55000-280	XP95 Flame Detector (IR2)
55000-295	XP95 Exd Flame Detector (IR2) - Flameproof

Apollo Fire Detectors Limited

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK t +44 (0)23 9249 2912 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

www.apollo-fire.co.uk







Base mounted flame detector dates

Approval	Estimated Approval Completion	Estimated resumption of Stock into Apollo
BRE, UKCA, LPCB	April 2024	May 2024

All products of the model numbers identified below are affected by this issue.

Model number	Item Name
55000-023	XP95 Flame Detector (UV/IR2) - Base Mount
55000-024	XP95 Flame Detector (IR3) - Base Mount
55000-028MAR	XP95 Marine Flame Detector (UV/IR2) - Base Mount
55000-029MAR	XP95 Marine Flame Detector (IR3) - Base Mount

Remedy:

Unfortunately, Apollo Fire Detectors Ltd are unable to offer any alternative products using IR sensors until the above-mentioned approvals and updates are completed. The below listed base mounted Flame detectors are available.

Model number	Item Name
55000-022	XP95 Flame Detector (UV) - Base Mount
55000-025	Series 65 Flame Detector (UV) - Base Mount
55000-026MAR	Series 65 Marine Flame Detector (UV) - Base Mount

Questions:

Should you have any further questions, please do not hesitate to contact the account manager or techsales@apollo-fire.com



